



# NSF Product and Service Listings

These NSF Official Listings are current as of Monday, October 19, 2015 at 12:15 a.m. Eastern Time. Please [contact NSF International](#) to confirm the status of any Listing, report errors, or make suggestions.

Alert: NSF is concerned about fraudulent downloading and manipulation of website text. Always confirm this information by clicking on the below link for the most accurate information: <http://info.nsf.org/Certified/PwsComponents/Listings.asp?Company=0C660&Standard=061&>

## NSF/ANSI 61

### Drinking Water System Components - Health Effects

NOTE: Unless otherwise indicated for Materials, Certification is only for the Water Contact Material shown in the Listing. [Click here for a list of Abbreviations used in these Listings.](#) [Click here for the definitions of Water Contact Temperatures denoted in these Listings.](#)

#### Kryton International Inc.

1645 East Kent Avenue  
Vancouver, BC V5P 2S8

Facility : Vancouver, British Columbia, Canada

#### Protective (Barrier) Materials

Trade Designation	Water Contact Size Restriction	Water Contact Temp	Water Contact Material
<b>Concrete Admixtures</b>			
KIM-AE	[1]	C. HOT	CMNT
KIM-ES	[1]	C. HOT	CMNT
KIM-HS	[1]	C. HOT	CMNT
Krystol Internal Membrane	[1]	C. HOT	CMNT
Krystol Repair Grout	[1]	C. HOT	CMNT
Krystol T1	[1]	C. HOT	CMNT
Krystol T2	[1]	C. HOT	CMNT
Krystol Waterstop Grout	[1]	C. HOT	CMNT
Krystol Waterstop Treatment	[1]	C. HOT	CMNT

[1] Certified for use in tanks 6000 gallons and greater. Maximum use level of admixture is 2% of cement by mass.